

1. The plan and the information contained herein is privileged and is given solely to the intended recipient for the specific purpose in which the plan is given. No part of the plan shall be reproduced or circulated to others under any circumstances.
2. The information of the watermain on this plan is valid as at date plotted and is given without any liability for any error, mis-statement or omission therein.
3. Position of watermain and the boundary lines of the water catchment indicated on this plan are approximate only. Smaller submains and connections to customers' premises/properties are not indicated. Trial holes must be carried out to determine the exact alignments and levels of all watermain before commencement of any earthworks.
4. The cost of diversions, if required, of any watermain shall be borne by owner / developer. For watermain of 500mm diameter and above, these are our vital trunk mains and diversions should be avoided unless absolutely necessary. Owner / developer shall determine by means of trial holes the exact alignment and levels of all existing watermain during the design stage and let PUB know whether they are affected by the proposed work so that PUB can advise whether diversion is required. If deem necessary by PUB, the affected watermain shall be diverted and the cost of diversion shall be borne by owner / developer. The cost of diversion shall be finalized upon confirmation on the length of watermain affected.
5. All other necessary precautions must be taken to safeguard and to avoid the damaged to the watermain. The cost of repairs to any watermain damaged as a result of work carried out is to be borne by party which causes the damage. The party will also be billed for the repair of the mains and the estimated quantities of water lost from the damaged mains. The party will also be required to indemnify PUB against all losses and claims arising from damage to watermain.
6. Please inform PUB 24-hour Call Centre at Tel No 1800-CALL PUB (1800-2255782) immediately in the event of damaged to watermain.

Type of Water Mains:

PUB Water Mains

NEWater Mains

Industrial Water Mains

Raw Water Mains

Dia

NW - Dia

IW - Dia

RW - Dia

Legend:

Existing Water Mains

Proposed Water Mains

Water Mains Under Construction

Abandoned Water Mains

Water Chamber

Double Pillar Hydrant

Ground Pillar Hydrant

Triple Pillar Hydrant

PUB Installation

Drain Line

The Proposed Site is outlined in YELLOW



0 4.5 9 13.5 18 22.5 Meters
SCALE 1:1,000

DONE BY: Generated by PCCSATE: 31/01/2024